

August 26, 2022

MEMORANDUM

TO: Prospective Bidders

FROM: Mike Apke, P.E.
Public Services and Engineering Director

SUBJECT: Addendum # 1
2023 Annual Street Resurfacing & Improvements
Village of Pinehurst

The following information will serve as Addendum #1 to the referenced bid package. **Please review all items, sign in the appropriate spaces at the end of this document, and include this document/acknowledgement in your bid submittal.** The bid opening for this project remains scheduled for **Tuesday, August 30th, 2022 at 2:00 p.m.** at Village Hall, 395 Magnolia Road, Pinehurst, North Carolina.

1. **Patching Depth** – To clarify, Contractors shall assume a patching depth of 3-inches as noted in Item 2 in the Itemized Proposal Form. In cases where patching greater than 3-inches is needed, the Contractor and Village will negotiate a price adjustment prior to proceeding with the work.

Certification of Receipt & Acknowledgement for Addendum #1

2023 Annual Street Resurfacing & Improvements

Name (Print): _____

Name (Signature): _____

Date: _____

Title: _____

Company: _____