

November 27, 2023

MEMORANDUM

TO: Prospective Bidders

FROM: Mike Apke, P.E.
Public Services and Engineering Director

SUBJECT: Addendum #1
FY24 Annual Street Resurfacing & Improvements
Village of Pinehurst

The following information will serve as Addendum #1 to the referenced bid package. **Please review all items, sign in the appropriate spaces at the end of this document, and include this document/acknowledgement in your bid submittal.** The bid opening for this project remains scheduled for **Thursday, November 30th, 2023 at 2:00 p.m.** at Village Hall, 395 Magnolia Road, Pinehurst, North Carolina.

1. **Utility Adjustments** – In addition to cast iron risers being allowed for adjustments of manholes and water valve boxes, composite manhole and valve adjustment rings as manufactured by the F.J. Turner Company are approved for use on this project.
2. **Clarifications on FDR specifications** – for bidding purposes, please assume a cement application rate of 45-50 lbs. per square yard. In addition, please remove the first 2 paragraphs in Part 5.06 of Section 5.00 of the Bid Documents that reference payment of stabilized material by the square yard and payment of Portland cement by the ton. The bid price for the FDR work shall be a lump sum as noted in the Itemized Proposal Form.

**Certification of Receipt & Acknowledgement for Addendum #1
FY24 Annual Street Resurfacing & Improvements**

Name (Print): _____

Name (Signature): _____

Date: _____

Title: _____

Company: _____